



STATE OF TENNESSEE  
**DEPARTMENT OF ENVIRONMENT AND CONSERVATION**  
DIVISION OF UNDERGROUND STORAGE TANKS  
4<sup>th</sup> FLOOR, L & C TOWER  
401 CHURCH STREET  
NASHVILLE, TENNESSEE 37243-1541

**Daily Record of Visual Inspection for Incompatible Dispenser Components**

Dispensers that are **not** certified by the manufacturer or UL Marked as E-Blend compatible (greater than 10% Ethanol) may be used with E-Blend fuel if a daily visual inspection is conducted by the owner/operator or someone authorized by the owner/operator. The components below must be visually inspected daily for leaks and failures. Any component that leaks or does not operate as designed must be replaced with a compatible component. **Contact the Division immediately if you observe a leak or failure.** Record inspections on this form and retain these records for 1 year. Keep this record on site or available for submittal to the Division within 72 hours. **If a leak is found, write LEAK in the box. For no leak, put an X in the box.**

Facility# \_\_\_\_\_ Month \_\_\_\_\_ Year \_\_\_\_\_

Day	Seals/ Gaskets	Filter	Suction Pump	Hoses	Meter	Break away	Nozzle/ Swivel	Dispenser Sump Dry? Y/N	Pipe Joints	Flex Connector	Shear Valve	Check Valve	Inspector
1													
2													
3													
4													
5													
6													
7													
8													
9													
10													
11													
12													
13													
14													
15													
16													
17													
18													
19													
20													
21													
22													
23													
24													
25													
26													
27													
28													
29													
30													
31													

COMMENTS \_\_\_\_\_